

Dt. 18.07.2024.

Salem. 636 001.

**NO OBJECTION CERTIFICATE**

**Sub:-** TamilNadu Fire and Rescue Services – Office of the Fire and Rescue Station, Salem – Issue to No objection Certificate for School Recognition – Regarding.

**Ref:-**

1. Government Order No. 117, School Education (Q1) Department, Dated. 07.09.2004
2. Government Order No. 122, School Education (2) Department, Dated. 14.09.2004
3. Government Order No. 123, School Education (2) Department, Dated. 14.09.2004
4. Application dated 16.07.2024 from the Correspondent of ROYAL PARK SCHOOL (CBSE), kumaragiri, south Ammapet, Salem-636015.

With reference to the above Government Orders and an Application by ROYAL PARK SCHOOL (SENIOR SECONDARY CBSE SCHOOL), S.No:264/1A, 264/1B & 258/14A, T.S.NO:5/8, 5/5 & 6/27, ward-AL, Block-16 Attur Bypass Road, Kumaragiri, South Ammapet, Salem Town, Salem Taluk, Salem District, salem-636015 was inspected on 18.07.2024 by Thiru. P.Sivakumar, Assistant District Officer, Salem Fire and Rescue Station in the view of our Fire and Rescue Services Department there is NO OBJECTION for granting Recognition to the above said School.

This certificate is valid up to 17.07.2025.

**Conditions:**

1. This Certificate is valid for One Year from the date of issue.
2. Fire Protection devices shall be placed in (Generator room, Class room, Laboratory and Computer room) the wall or easy to handle as per provisions of National Building code 2015 and Indian Standards.
3. Water Tanks should always be kept in full.
4. Mock drill should be conducted periodically.
5. Emergency exit signs should be in red colour that even glows in the dark.
6. First Aid kit should be kept and used properly.
7. Do not accumulate waste materials in the School premises.
8. Cooking room should be separate from the School building and LPG gas cylinders should be used safely without leakage.



*[Signature]*  
Assistant District Officer  
Fire and Rescue Services  
Salem - 636 001  
Salem District

**To:-**

The Correspondent,  
ROYAL PARK SCHOOL (SENIOR SECONDARY CBSE SCHOOL),  
S.No:264/1A, 264/1B & 258/14A, T.S.NO:5/8, 5/5 & 6/27, ward-AL, Block-16  
Attur Bypass Road, Kumaragiri, South Ammapet, Salem Town,  
Salem Corporation Limit, Salem Taluk, Salem-636 015.

**Copy to:-**

1. The Joint Director, Fire and Rescue Services, Salem Region, Salem-16.
2. District Officer, Salem District.