



**SALEM CITY MUNICIPAL CORPORATION
SANITARY CERTIFICATE**

ROC: F3/11078/2023

Date: 31/07/2023

This is to certify that **Royal Park School, Senior Secondary CBSE School, Attur Bypass Road, Kumaragiri, South Ammapet, Salem-636 015.** has been inspected.

The building, the premises and the accommodation provided for the inmates is sufficient.

- It is properly ventilated and lighted,
- The building is maintained in substantial repair,
- It is neat and clean,
- The supply of drinking water is wholesome,
- In all other necessary respects the sanitation is good.

This certificate is valid for a period of one year from the date of issue and Subject to the following Conditions:

1. One time use throwaway plastic banned by Govt. should not be used.
2. One Sanitary worker should be appointed on rotation to keep the toilet clean at all times
3. The general instructions given in the annexure has to be followed scrupulously without any lapses.
4. Dengue(Aedes) free campus certification has to be submitted every Thursday.

"NO SMOKING AREA. SMOKING HERE IS AN OFFENCE"

under section 4 of COTPA 2003

The certificate is liable to be cancelled if the conditions given in Annexure-I&II as guidelines for preventing COVID-19 & Dengue are not satisfied within 1 month of issuing or if there is violation of rules on subsequent inspection.

This Certificate is valid till 30.07.2024 only.

Place: Salem.
Date :31.07.2023



[Signature]
31/07/2023
Deputy Director/City Health Officer,
Salem City Municipal Corporation.

For Royal Park School

[Signature]
Correspondent

[Signature]
THE PRINCIPAL
ROYAL PARK SCHOOL
Attur By-Pass Road, South Ar
Kumaragiri, SALEM



: TEST WATER BEFORE TASTE :

**TAMIL NADU WATER SUPPLY & DRAINAGE BOARD
DISTRICT LEVEL WATER TESTING LABORATORY**

TWAD Board, No 397 ANBU NAGAR GORIMEDU SALEM-8 PIN 636 008

TEST REPORT

Ph: 0427-2405687

From
Er. J.Suthakar B.E.,
Assistant Executive Engineer
TWAD Board
RWS Sub Division
Salem

To
THE ROYAL PARK SCHOOL
Attur Bypass Road
Kumaragiri, South Ammapet
Salem- 636015

Lr.No: 57089-57090 /AEE/TWAD Lab/ Salem/2021/Dated: 04.10.2021

Sir,

Sub: Examination of water sample - Report furnished - Reg.

Ref : 1) Letter dated: 29.09.2021

2) T.O Invoice No. 6316 /Dt: 29.09.2021 for Rs 1652/-

The results of analysis for the water sample sent under reference is furnished below.

Sample No	57089
Date of Collection	29.09.21
Date of Receipt	29.09.21
Scheme	-
Source	RO Plant Water
Location of Sampling	THE ROYAL PARK SCHOOL
Habitation	Kumaragiri
Panchayat	
Union	Salem
Collected by	Mrs.Sangeetha
BIS 10500 : 2012	
I PHYSICAL EXAMINATION	
1 Appearance	Clear
2 Colour (Pt.Co - scale)	Colourless
3 Odour	None
4 Turbidity NT units	0
5 Total dissolved solids, mg/L	104
6 Electrical conductivity micro mho/cm	148
II CHEMICAL EXAMINATION	
7 pH	7.65
8 Ph-Alkalinity as CaCO ₃ mg/L	0
9 Total Alkalinity CaCO ₃ mg/L	44
10 Total Hardness as CaCO ₃ mg/L	36
11 Calcium as Ca mg/L	8
12 Magnesium as Mg mg/L	2
13 Sodium as Na mg/L	20
14 Potassium as K mg/L	1
15 Iron as Fe mg/L	0.0
16 Manganese as Mn mg/L	0.0
17 Free Ammonia as NH ₃ mg/L	0.0
18 Nitrite as NO ₂ mg/L	0.0
19 Nitrate as NO ₃ mg/L	1
20 Chloride as Cl mg/L	16
21 Fluoride as F mg/L	0.2
22 Sulphate as SO ₄ mg/L	7
23 Phosphate as PO ₄ mg/L	0.0
24 Tidy's Test 4hrs as O ₂ mg/L	0.24
25 Free residual chlorine mg/L	0.0
III BACTERIOLOGICALEXAMINATION	
1 Fecal coliform (colonies per 100 ml)	0

REPORT: 57089-57090 : The given water sample is Physically, Chemically potable and Bacteriologically not contaminated.

For Royal Park School

M. S. Sathya
Correspondent

D. S. Sathya
Assistant Executive Engineer/TWAD
RWS Sub Division/Salem

**THE PRINCIPAL
ROYAL PARK SCHOOL**
Attur By-Pass Road, South Ammapet
Kumaragiri, Salem